

General: *Revised Company name and logo to Oncor Electric Delivery throughout specifications.*

DDS-1 – Specification for Electrical Service Lateral Raceways- Single Unit & Duplex Residential:

Eliminated reference to rigid conduit on detail sheet 3. Revised detail sheets 5, 6, 7 and 10 to reflect standard drawing revisions.

DDS-1MH – Specification for Electrical Service Lateral Raceways- Residential Mobile Homes:

Revised 6.3 in text to eliminate rigid conduit. Eliminated reference to rigid conduit on detail sheet 2. Revised detail sheets 4, 5, 6 and 9 to reflect standard drawing revisions.

DDS-1PR - Specification for Electrical Service Lateral Raceways- Pool Re-routes :

Revised 6.2 in text to eliminate rigid conduit. Eliminated reference to rigid conduit on detail sheet 1. Revised detail sheets 3, 4 and 7 to reflect standard drawing revisions.

DDS-2 - Specifications for Electrical Underground Residential Distribution Systems:

Revised 6.7 in text to eliminate rigid conduit. Eliminated reference to rigid conduit on detail sheet 1. Revised detail sheets 8, 18, 19 and 20 to reflect standard drawing revisions.

DDS-3OH - Specifications for Electrical Underground Distribution Systems from Overhead Transformation, Apartments & Condominiums:

Revised 6.7 in text to eliminate rigid conduit. Added note 6.18 in text for identification of meters. Eliminated reference to rigid conduit on detail sheet 1. Revised detail sheets 3, 4, 5 and 8 to reflect standard drawing revisions.

DDS-3UG - Specifications for Electrical Underground Distribution Systems from Padmounted Transformation, Apartments & Condominiums:

Revised 6.7 in text to eliminate rigid conduit. Added note 6.24 in text for identification of meters. Eliminated reference to rigid conduit on detail sheet 1. Revised detail sheets 8, 17, 18 and 19 to reflect standard drawing revisions.

DDS-4OH - Specifications for Electrical Underground Distribution Systems from Overhead Transformation, Secondary Service Accounts:

Revised 6.7 in text to eliminate rigid conduit. Added note 6.21 in text for identification of meters. Eliminated reference to rigid conduit on detail sheet 1. Revised detail sheets 3, 4, 5 and 8 to reflect standard drawing revisions.

DDS-4UG - Specifications for Electrical Underground Distribution Systems from Padmounted Transformation, Secondary Service Accounts:

Revised 6.7 in text to eliminate rigid conduit. Added note 6.25 in text for identification of meters. Eliminated reference to rigid conduit on detail sheet 1. Revised detail sheets 7, 36, 41, 43 and 44 to reflect standard drawing revisions. Added new underground standard 205-346 as new detail sheet 42.